

MUNICIPAL CORPORATION CHANDIGARH
(Medical Officer of Health)

(SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE)
(NO OBJECTION CERTIFICATE)

No. MOH/Supdt.Admn/NOC/2025/

14621

Dated:-

13/11/25

It is certified that an inspection team headed by Sh Darshan Singh, Chief Sanitary Inspector from Office of Medical Officer of Health, Municipal Corporation Chandigarh inspected the Modern Ways Model School, Sector 29-C, Chandigarh on 30-10-2025 and mentioned in inspection report that Modern Ways Model School, Sector 29-C, Chandigarh is maintaining the hygienic sanitation condition in the premises as per the norms prescribed by the Central/State/U.T Govt. India.

The above Certificate is valid for a period of One-year w.e.f 20.09.2025 (i.e. Water Sampling Date).



Medical Officer of Health
Municipal Corporation
Chandigarh

To

Modern Ways Model School,
Sector 29-C,
Chandigarh



MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

TEST - REPORT
Not for legal use

Lab No. : MCPHL/25/ 3242

Date : 20.09.2025

Ref. No. : Health01	Sample Details	Date & Time
Dated : 15.09.2025		
Issued to : The Principal Modern ways Model School, Sector - 29-C, Chandigarh	Collected By : Laboratory Staff	Collection Date : 16.09.2025
Location : From School tap of Modern ways Model School, Sector - 29-C, Chandigarh	Collection Date : 06:00p.m	Received at Lab : 08:40p.m.
Packing : Polypropylene and glass bottle		

Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	---	7.70
2	Odour	Agreeable	---	Agreeable
3	Taste	Agreeable	---	Agreeable
4	Turbidity	<1	N.T.U.	0.8
5	Total Dissolved Solids	<500	mg/l	142
6	Residual Chlorine	0.2 - 0.4	mg/l	0.2
7	Total Alkalinity (as CaCO ₃)	<200	mg/l	98
8	Total Hardness (as CaCO ₃)	<200	mg/l	80
9	Chlorides (as Cl)	<250	mg/l	04
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0

(Excellent)

Payment received vide receipt No. 09/2025-26/273097 dated 15.09.2025, amount Rs.-3300/-

Note: - Water sample is found "POTABLE"

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Endst. No. MCPH/25/-----

Dated : 20.09.2025

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector -17, Chandigarh for Information please.

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or legal purpose.

----- End of Report -----

WATER IS LIFE, SAVE IT